

The manufacturer is granted the following type test approval mark in virtue of a test report:

Category test approval mark: [safety valve](#)

Technical inspection and surveillance organisation and test report: TÜV Rheinland Industrie Service GmbH dated 2022-07-20

Manufacturer/Circulator: [Goetze KG Armaturen](#)  
[Robert-Mayer-Str. 21](#)  
[71636 Ludwigsburg](#)  
[GERMANY](#)

Type test approval mark: [TÜV . SV . 22 - 2094 . d<sub>0</sub> . S/G .  \$\alpha\_w\$  . p](#)  
[TÜV . SV . 22 - 2094 . d<sub>0</sub> . D/G/H .  \$\alpha\_w\$  . p](#)  
[TÜV . SV . 22 - 2094 . d<sub>0</sub> . L .  \$\alpha\_w\$  . p](#)  
[TÜV . SV . 22 - 2094 . d<sub>0</sub> . F/K/S .  \$\alpha\_w\$  . p](#)

Design: [direct acting safety valve, spring loaded](#)

Type: [255, 355 and 455](#)

The adjudication is made pursuant to:

- VdTÜV-Merkblatt Sicherheitsventil 100, edition 2017-04-13, in conjunction with VdTÜV-Merkblatt General 002, edition 2019-02-22
- AD 2000-Merkblätter A 2, edition 2020-01, and A 4, edition 2015-11
- essential safety requirements of Directive 2014/68/EU from 15.05.2014 (Pressure Equipment Directive)
- DIN EN ISO 4126-1:2013 + A1:2016 + A2:2019
- DIN EN ISO 4126-7:2013 + A1:2016
- EN 12828:2012 + A1:2014, Annex E

Valid until: [2027-12-31](#)

The adjudication is revocable. The previous certificate is replaced herewith.

Note: The manufacturer or importer is obliged to the competent Authorized Inspector to conduct a random check on the accessories concerning identity to the type once a year. The accessories have to be taken from the current production.

TÜV-Verband e. V.  
Friedrichstraße 136  
10117 Berlin

phone: +49 30 760095-400  
e-mail: [bauteile@tuev-verband.de](mailto:bauteile@tuev-verband.de)

---

division industry and plant engineering

[www.tuev-verband.de/en](http://www.tuev-verband.de/en)